



Test Report issued under the responsibility of:



TEST REPORT
IEC 60950-1
Information technology equipment – Safety –
Part 1: General requirements

Report Number : CB191115-01-A3
Date of issue : 2014-10-15, Amendment No. 3: 2019-12-02
Total number of pages..... 19

**Name of Testing Laboratory
preparing the Report.....** : Prodigy Technology Consultant Co., Ltd.

Applicant's name..... : INNOLUX CORP
Address : 160 KESYUE RD JHUNAN SCIENCE PARK MIAOLI HSIEN, 350
TAIWAN

Test specification:

Standard..... : IEC 60950-1:2005, AMD1:2009, AMD2:2013
Test procedure : CB Scheme
Non-standard test method : N/A

Test Report Form No. : IEC60950_1G
Test Report Form(s) Originator : SGS Fimko Ltd
Master TRF..... : Dated 2019-07-02

Copyright © 2019 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.
This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test item description.....:	LCD Module
Trade Mark.....:	1)  2) mitsubishi electric
Manufacturer	Same as applicant
Model/Type reference.....:	1) G156BGE-LXX, G156HCE-LXX, G156HCE-EXX (X can be 0-9, A-Z or blank for marketing purpose and no impact safety related critical components and constructions) 2) AC156GA01
Ratings.....:	(Optional) 5.5Vdc max., 0.32A max. (For LCD Panel with control board); 13.2Vdc max., 1A max. (For DC/DC Converter board); 3.6Vdc max., 1.5A max. (For LCD Panel with DD Converter circuit control board A, C, D) 5.5Vdc max., 0.32A max. (For LCD Panel with DD Converter circuit control board B)

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
☒	CB Testing Laboratory:	
Testing location/ address		Prodigy Technology Consultant Co., Ltd. / No.181, Sec. 2, Wunhua 1st Rd., Linkou District, New Taipei City 244, Taiwan CHINESE TAIPEI
Tested by (name, function, signature)..... :		Yama Cheng / Project Handler 
Approved by (name, function, signature)... :		Frank Chang / Reviewer 
☐	Testing procedure: CTF Stage 1:	
Testing location/ address		
Tested by (name, function, signature)..... :		
Approved by (name, function, signature)... :		
☐	Testing procedure: CTF Stage 2:	
Testing location/ address		
Tested by (name + signature)		
Witnessed by (name, function, signature) . :		
Approved by (name, function, signature)... :		
☐	Testing procedure: CTF Stage 3:	
☐	Testing procedure: CTF Stage 4:	
Testing location/ address		
Tested by (name, function, signature)..... :		
Witnessed by (name, function, signature) . :		
Approved by (name, function, signature)... :		
Supervised by (name, function, signature) :		

List of Attachments (including a total number of pages in each attachment): National Differences (164 pages) Enclosures (6 pages)	
Summary of testing:	
Tests performed (name of test and test clause): Input Test: Single-Phase (1.6.2) SELV Reliability Test Including Hazardous Voltage Measurements (2.2.2, 2.2.3, 2.2.4, PART 22 6.1) Heating Testing (4.5.1, 1.4.12, 1.4.13)	Testing location: Prodigy Technology Consultant Co., Ltd. / No.181, Sec. 2, Wunhua 1st Rd., Linkou District, New Taipei City 244, Taiwan CHINESE TAIPEI
Summary of compliance with National Differences: List of countries addressed: For IEC 60950-1:2005 (Second Edition) + Am 1:2009 + Am 2:2013 Australia (AU), Austria (AT), Denmark (DK), Group (EU), Italy (IT), Sweden (SE), Turkey (TR), United Kingdom (GB), United States of America (US), Canada (CA), Argentina (AR), Belarus (BY), Belgium (BE), Bulgaria (BG), Switzerland (CH), China (CN), Czech Republic (CZ), Germany (DE), Spain (ES), France (FR), Greece (GR), Hungary (HU), Ireland (IE), Israel (IL), India (IN), Japan (JP), Republic of Korea (KR), Malaysia (MY), Netherlands (NL), Norway (NO), New Zealand (NZ), Poland (PL), Portugal (PT), Romania (RO), Saudi Arabia (SA), Singapore (SG), Slovenia (SI), Slovakia (SK), Ukraine (UA), South Africa (ZA) For IEC 60950-1:2005 (Second Edition); Am 1:2009 Argentina (AR), National Differences for Australia (AU), Canada (CA), Germany (DE), Denmark (DK), Group (EU), Finland (FI), United Kingdom (GB), Israel (IL), Japan (JP), Korea (KR), Norway (NO), Sweden (SE), Slovenia (SI), United States of America (US), New Zealand (NZ) For IEC 60950-1:2005 (2 nd Edition) National Differences for Austria (AT), Australia (AU), Canada (CA), Switzerland (CH), China (CN), Germany (DE), Denmark (DK), Spain (ES), Group (EU), Finland (FI), France (FR), United Kingdom (GB), Ireland (IE), Italy (IT), Israel (IL), Japan (JP), Korea (KR), The Netherlands (NL), Norway (NO), Poland (PL), Sweden (SE), Slovenia (SI), United States of America (US), New Zealand (NZ) as listed in the CB Bulletin No. 112A (December 2006) are recorded. ☒ The product fulfils the requirements of <u>EN 60950-1:2006 +A11:2009 +A1:2010 +A12:2011 +A2:2013 and AS/NZS 60950.1:2015</u>	
Copy of marking plate: The artwork below may be only a draft (See Enclosure/Marking Plate ID 13-01 for detail). The use of certification marks on a product must be authorized by the respective NCBs that own these marks.	

Test item particulars.....:	
Equipment mobility.....:	☐ movable ☐ hand-held ☐ transportable ☐ stationary ☒ for building-in ☐ direct plug-in
Connection to the mains.....:	☐ pluggable equipment ☐ type A ☐ type B ☐ permanent connection ☐ detachable power supply cord ☐ non-detachable power supply cord ☒ not directly connected to the mains
Operating condition.....:	☒ continuous ☐ rated operating / resting time:
Access location	☒ operator accessible ☐ restricted access location
Over voltage category (OVC)	☐ OVC I ☐ OVC II ☐ OVC III ☐ OVC IV ☒ other: evaluated at end product
Mains supply tolerance (%) or absolute mains supply values	No direct connection
Tested for IT power systems	☐ Yes ☒ No
IT testing, phase-phase voltage (V)	N/A
Class of equipment	☐ Class I ☐ Class II ☒ Class III ☐ Not classified
Considered current rating of protective device as part of the building installation (A)	N/A (evaluated at end product)
Pollution degree (PD)	☐ PD 1 ☒ PD 2 ☐ PD 3
IP protection class	IPX0
Altitude during operation (m)	Up to 2000 m
Altitude of test laboratory (m)	Up to 2000 m
Mass of equipment (kg)	1.19 kg max.

Possible test case verdicts:	
- test case does not apply to the test object	N/A
- test object does meet the requirement	P (Pass)
- test object does not meet the requirement	F (Fail)
Testing.....:	
Date of receipt of test item.....:	2019-11-14
-Date (s) of performance of tests	2019-11-20 to 2019-11-21
General remarks:	
"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report. Throughout this report a ☐ comma / ☒ point is used as the decimal separator.	

Manufacturer's Declaration per sub-clause 4.2.5 of IEC60950-1:	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided..... :	☒ Yes ☐ Not applicable
When differences exist; they shall be identified in the General product information section.	
Name and address of factory (ies) :	1) Innolux Corporation No.3 Sec. 1, Huanshi Rd. Southern Taiwan Science Park, Tainan Hsien, 74147 Taiwan. 2) Innolux Corporation No.12 Nanke 8th Rd., Southern Taiwan Science Park, Tainan Hsien, 74144 Taiwan. 3) Foshan Innolux Optoelectronics Ltd. Xingye North Road., Nanhai Science & Technology Industry Park, Shishan Township, Nanhai District, Foshan City, Guangdong Province, 528237 China. 4) Ningbo Innolux Optoelectronics Ltd. Ningbo Export Processing Zone, 16 Yangzi River North Rd., Ningbo Zhejiang, 315800 China. 5) Ningbo Innolux Optoelectronics Ltd. No.6 Yangzi River S Rd., Ningbo Export Processing Zone. Ningbo Zhejiang, 315800 China. 6) Ningbo Innolux Technology Ltd. 8 Caoe Rd., Bonded Southern District, Ningbo Zhejiang, 315000 China. 7) Ningbo Innolux Display Ltd. 8 Caoe Rd., Bonded Southern District, Ningbo Zhejiang, 315000 China.
Report Summary	
All applicable tests according to the referenced standard(s) have been carried out. - This test Report should be read in conjunction with the original report No. CB141002-02-A0, issued 2014-10-15 with CB certificate No. (DK-41490-UL, DK-41491-UL), issue 2014-10-20. CB170512-03-A1, issued 2017-06-07 with CB certificate No. (DK-41490-A1-UL, DK-41491-A1-UL), issue 2017-06-13. CB180712-01-A2, issued 2018-07-25 with CB certificate No. (DK-41490-A2-UL, DK-41491-A2-UL), issue 2018-07-30. (Technical Amendment) This Test Report were deemed to amend, due to: 1) Add one model name: G156HCE-EXX 2) Add one DD converter circuit control board D 3) Modify one rating from 3.6Vdc max, 1.5A max. (For LCD Panel with DD Converter circuit control board A, C) to 3.6Vdc max, 1.5A max. (For LCD Panel with DD Converter circuit control board A, C, D) 4) Update Trade mark from  MITSUBISHI ELECTRIC to MITSUBISHI ELECTRIC 5) Update National Difference 6) Revised TRF no. from IEC60950_1F to IEC60950_1G.	

7) Revised Report Reference No. from "CB180712-01-A2" to "CB191115-01-A3"

Product Description

Electronic components were mounted on PWB, incorporated with 15.6 inch wide TFT-LCD panel, and LED Backlight

Model Differences

All models are identical except for model designation.

Additional Information

- The label is a draft of an artwork for marking plate pending approval by National Certification Bodies and it shall not be affixed to products prior to such an approval.
- Additional investigation in accordance with EN 60950-1:2006+A11:2009+A1:2010+A12:2011+A2:2013 and AS/NZS 60950.1:2015
- The product was submitted and evaluated for use at the maximum ambient temperature (Tma) permitted by the manufacturer's specification of: 60 degree C (excluding DD converter circuit control board C), 85 degree C (only for DD converter circuit control board C).
- The Input and Heating Test shall be conducted in the end-use product.
- The following end-product enclosures are required: Mechanical, Fire, Electrical
- The following are available from the Applicant upon request: Installation (Safety) Instructions / Manual.
- The following rating are for each converter circuit control board:
 13.2 Vdc max., 1.05 A max. (For DD converter circuit control board A)
 13.2 Vdc max., 1.2 A max. (For DD converter circuit control board B)
 13.2 Vdc max., 1.2 A max. (For DD converter circuit control board C)
13.2 Vdc max., 1.0 A max. (For DD converter circuit control board D)

Abbreviations used in the report:

- normal conditions	N.C.	- single fault conditions	S.F.C
- functional insulation	OP	- basic insulation	BI
- double insulation	DI	- supplementary insulation	SI
- between parts of opposite polarity	BOP	- reinforced insulation	RI

Indicate used abbreviations (if any)

IEC 60950-1			
Clause	Requirement + Test	Result - Remark	Verdict

1	GENERAL		Pass
----------	----------------	--	------

1.5	Components		Pass
1.5.1	General	See below.	Pass
	Comply with IEC 60950-1 or relevant component standard	(see appended table 1.5.1)	Pass
1.5.2	Evaluation and testing of components	Components certified to IEC harmonized standard and checked for correct application. Components, for which no relevant IEC-Standard exist, have been tested under the conditions occurring in the equipment, using applicable parts of IEC 60950-1. Components not certified are used in accordance with their ratings and they comply with applicable parts of IEC 60950-1 and the relevant component Standard.	Pass

1.6	Power interface		Pass
1.6.1	AC power distribution systems	AC power distribution systems are classified as TN.	Pass
1.6.2	Input current	The steady state input current of the equipment did not exceed the RATED CURRENT by more than 10% under normal load (See appended table 1.6.2 for details).	Pass
1.6.3	Voltage limit of hand-held equipment	This is not a hand-held equipment.	N/A
1.6.4	Neutral conductor	Evaluated as a part of certified power supply.	N/A

1.7	Marking and instructions		Pass
1.7.1	Power rating and identification markings	Class III unit intended to be supplied by an external non energy hazardous SELV power supply. (Optional)	Pass
1.7.1.1	Power rating marking		Pass
	Multiple mains supply connections.....:		Pass

IEC 60950-1			
Clause	Requirement + Test	Result - Remark	Verdict
	Rated voltage(s) or voltage range(s) (V)	(Optional) 5.5Vdc max. (For LCD Panel with control board); 13.2Vdc max. (For DC/DC Converter board); 3.6Vdc max. (For LCD Panel with DD Converter circuit control board A, C, D) 5.5Vdc max. (For LCD Panel with DD Converter circuit control board B)	Pass
	Symbol for nature of supply, for d.c. only.....	Optional ,  (60417-2-IEC-5031)	N/A
	Rated frequency or rated frequency range (Hz)		N/A
	Rated current (mA or A)	(Optional) 0.32A max. (For LCD Panel with control board); 1A max. (For DC/DC Converter board); 1.5A max. (For LCD Panel with DD Converter circuit control board A, C, D) 0.32A max. (For LCD Panel with DD Converter circuit control board B)	Pass
1.7.1.2	Identification markings	See below	Pass
	Manufacturer's name or trade-mark or identification mark	1)  2) 	Pass
	Model identification or type reference	1) G156BGE-LXX, G156HCE-LXX, G156HCE-EXX (X can be 0-9, A-Z or blank for marketing purpose and no impact safety related critical components and constructions) 2) AC156GA01	Pass
	Symbol for Class II equipment only		N/A
	Other markings and symbols	Additional symbols may be provided when submitted for National Approval.	N/A

2	PROTECTION FROM HAZARDS	Pass
----------	--------------------------------	------

2.2	SELV circuits		Pass
2.2.1	General requirements	The unit intended to be supplied by SELV.	Pass
2.2.2	Voltages under normal conditions (V):	All accessible voltages are less than 42.4 V peak or 60 V dc and are classified as SELV.	Pass
2.2.3	Voltages under fault conditions (V):		Pass
2.2.4	Connection of SELV circuits to other circuits:	SELV circuits are only connected to other SELV circuit.	Pass

IEC 60950-1			
Clause	Requirement + Test	Result - Remark	Verdict

4	PHYSICAL REQUIREMENTS		Pass
----------	------------------------------	--	------

4.5	Thermal requirements		Pass
4.5.1	General		Pass
4.5.2	Temperature tests	The equipment and its component parts did not attain excessive temperatures during normal operation. (See appended table 4.5 for details)	Pass
	Normal load condition per Annex L :	See appended table 4.5 for details	—
4.5.3	Temperature limits for materials	See appended table 4.5 for details	Pass
4.5.4	Touch temperature limits	See appended table 4.5 for details	Pass
4.5.5	Resistance to abnormal heat :		N/A

IEC 60950-1			
Clause	Requirement + Test	Result - Remark	Verdict

1.5.1	TABLE: List of critical components					Pass
Object/part No.	Manufacturer/ trademark	Type/model	Technical data	Standard (Edition / year)	Mark(s) of conformity ¹⁾	
01. LCD Panel	INNOLUX / MITSUBISHI ELECTRIC	G156BGE-LXX, G156HCE-LXX, G156HCE-EXX (X can be 0-9, A-Z or blank), AC156GA01	15.6 inch, TFT- LCD, LED backlight	--	--	
02. Printed Wiring Board (excluding DD converter circuit control board C)	Interchangeable	Interchangeable	V-1 minimum, 90 degree C minimum	UL 796	UL	
02a. Alternate Printed Wiring Board (Optional) (only for DD converter circuit control board C)	Interchangeable	Interchangeable	V-1 minimum, 105 degree C minimum	UL 796	UL	
03. DD Converter circuit Control board A (Optional)	INNOLUX / MITSUBISHI ELECTRIC	AC156GA01 / G156BGE-L02	13.2Vdc max., 1.05A max.	--	--	

Supplementary information:

¹⁾ Provided evidence ensures the agreed level of compliance. See OD-CB2039.

1.5.1	TABLE: Opto Electronic Devices	N/A
Manufacturer..... : Type : Separately tested : Bridging insulation..... : External creepage distance : Internal creepage distance : Distance through insulation : Tested under the following conditions : Input..... : Output..... : supplementary information --		

IEC 60950-1			
Clause	Requirement + Test	Result - Remark	Verdict

1.6.2	TABLE: Electrical data (in normal conditions)					Pass
U (V)	I (A)	I _{rated} (A)	P (W)	Fuse #	I _{fuse} (A)	Condition/status
5.5Vdc	0.21	0.32	1.16	--	--	Maximum Normal Load (For LCD Panel with Control board A)
13.2Vdc	0.69	1	9.11	--	--	Maximum Normal Load (For DC/DC Converter board)
3.6Vdc	0.332	1.5	1.20	--	--	Maximum normal load (For LCD Panel with DD Converter circuit Control board A)
13.2Vdc	0.765	1.05	10.10	--	--	Maximum normal load (For DD Converter circuit Control board A)
5.5Vdc	0.23	0.32	1.27	--	--	Maximum Normal Load (For LCD Panel with DD Converter circuit Control board B)
13.2Vdc	0.75	1.2	9.9	--	--	Maximum normal load (For DD Converter circuit Control board B)
5.5Vdc	0.228	0.32	1.16	--	--	Maximum Normal Load (For LCD Panel with Control board B)
3.6Vdc	0.908	1.5	3.27	--	--	Maximum Normal Load (For LCD Panel with DD Converter circuit Control board C)
13.2Vdc	0.762	1.2	10.06	--	--	Maximum normal load (For DD Converter circuit Control board C)
3.6Vdc	0.182	1.5	0.66	--	--	Maximum Normal Load (For LCD Panel with DD Converter circuit Control board D)
13.2Vdc	0.592	1.0	7.82	--	--	Maximum normal load (For DD Converter circuit Control board D)

Supplementary information:

"Maximum normal load" was defined as follows:

- Unit was maximum brightness and contrast with vertical stripe pattern and operation continuously.
(For DC/DC Converter board and for DD Converter circuit Control board B and for LCD Panel with Control board B)
- Unit was maximum brightness and contrast with horizontal stripe pattern and operation continuously.
(For DD Converter circuit Control board A)
- Unit was maximum brightness and contrast with white pattern and operation continuously.
(For DD Converter circuit Control board C)
- **Unit was maximum brightness and contrast with Mosaic pattern and operation continuously.
(For DD Converter circuit Control board D)**

IEC 60950-1			
Clause	Requirement + Test	Result - Remark	Verdict

2.1.1.5 c) 1)	TABLE: max. V, A, VA test			N/A
Voltage (rated) (V)	Current (rated) (A)	Voltage (max.) (V)	Current (max.) (A)	VA (max.) (VA)
--	--	--	--	--
supplementary information:				
--				

2.1.1.5 c) 2)	TABLE: stored energy			N/A
Capacitance C (μF)		Voltage U (V)	Energy E (J)	
--		--	--	
supplementary information:				
--				

2.2	TABLE: evaluation of voltage limiting components in SELV circuits			Pass
Component (measured between)	max. voltage (V) (normal operation)		Voltage Limiting Components	
	V peak	V d.c.		
For DC/DC Converter	--	--	--	
After L1 pin2– GND	32.8	--	--	
After D1 pin2 – GND	--	29.6	--	
For DD Converter circuit Control board A	--	--	--	
After L4 (VLED2)	44.8	--	--	
After D11 (VLED2)	--	31.6	D11	
For DD Converter circuit Control board B	--	--	--	
After L3– GND	41.6	--	--	
For DD Converter circuit Control board C	--	--	--	
After L4 to RTN	31.2	--	--	
For DD Converter circuit Control board D	--	--	--	
After LP1 to RTN	36	--	--	
After DP1 to RTN	--	28	--	
Fault test performed on voltage limiting components	Voltage measured (V) in SELV circuits (V peak or V d.c.)			
For DD Converter circuit Control board A	--			
D11 Pin1 – 2 short	14.0Vdc			
supplementary information:				
If the voltage exceeded 42.4 V pk or 60 V dc, the measurement was taken again after the next component in series with the secondary until the voltage measured was less than 42.4 V pk or 60 V dc. Each voltage measured and each component located in series directly before the measurement was noted. The following terminals were connected to earth GND : C128 Pin- Secondary return (for DD Converter circuit Control board C)				

IEC 60950-1			
Clause	Requirement + Test	Result - Remark	Verdict

2.5	TABLE: Limited power sources	N/A
------------	-------------------------------------	-----

Circuit output tested:

Note: Measured Uoc (V) with all load circuits disconnected:

Components	Test condition (Single fault)	Uoc (V)	I _{sc} (A)		VA	
			Meas.	Limit	Meas.	Limit
--	--	--	--	--	--	--

supplementary information:

Sc=Short circuit, Oc=Open circuit

2.10.2	Table: working voltage measurement	N/A
---------------	---	-----

Location	RMS voltage (V)	Peak voltage (V)	Comments
--	--	--	--

supplementary information:

--

2.10.3 and 2.10.4	TABLE: Clearance and creepage distance measurements	Pass
--------------------------	--	------

Clearance (cl) and creepage distance (cr) at/of/between:	U peak (V)	U r.m.s. (V)	Required cl (mm)	cl (mm)	Required cr (mm)	cr (mm)
--	------------	--------------	------------------	---------	------------------	---------

Functional:

--	--	--	--	--	--	--
----	----	----	----	----	----	----

Basic/supplementary:

--	--	--	--	--	--	--
----	----	----	----	----	----	----

Reinforced:

--	--	--	--	--	--	--
----	----	----	----	----	----	----

Supplementary information:

-This components is Class III (supplies by SELV) and merely functional insulation required.

2.10.5	TABLE: Distance through insulation measurements	N/A
---------------	--	-----

Distance through insulation (DTI) at/of:	U peak (V)	U rms (V)	Test voltage (V)	Required DTI (mm)	DTI (mm)
--	--	--	--	--	--

Supplementary information:--

4.3.8	TABLE: Batteries	N/A
--------------	-------------------------	-----

The tests of 4.3.8 are applicable only when appropriate battery data is not available

--

N/A

Is it possible to install the battery in a reverse polarity position?

--

N/A

	Non-rechargeable batteries	Rechargeable batteries
--	----------------------------	------------------------

IEC 60950-1									
Clause	Requirement + Test				Result - Remark			Verdict	
	Discharging		Un-intentional charging	Charging		Discharging		Reversed charging	
	Meas. current	Manuf. Specs.		Meas. current	Manuf. Specs.	Meas. current	Manuf. Specs.	Meas. current	Manuf. Specs.
Max. current during normal condition	--	--	--	--	--	--	--	--	--
Max. current during fault condition	--	--	--	--	--	--	--	--	--
--									
Test results:					--			Verdict	
- Chemical leaks					--			N/A	
- Explosion of the battery					--			N/A	
- Emission of flame or expulsion of molten metal					--			N/A	
- Electric strength tests of equipment after completion of tests					--			N/A	
Supplementary information: --									

4.3.8	TABLE: Batteries	N/A
Battery category.....: --		
Manufacturer.....: --		
Type / model.....: --		
Voltage.....: --		
Capacity.....: --		
Tested and Certified by (incl. Ref. No.).....: --		
Circuit protection diagram: --		
--		

MARKINGS AND INSTRUCTIONS (1.7.13)	
Location of replaceable battery	--
Language(s)	--
Close to the battery	--
In the servicing instructions	--
In the operating instructions	--

4.5	TABLE: Thermal requirements	Pass
	Supply voltage (V): See below See below -- -- --	—
	Ambient T _{min} (°C): -- -- -- -- --	—
	Ambient T _{max} (°C): -- -- -- -- --	—

IEC 60950-1						
Clause	Requirement + Test		Result - Remark			Verdict
Maximum measured temperature T of part/at.....:			T (°C)			Allowed T _{max} (°C)
For LCD Panel with Control board and DC/DC Converter board			Maximum normal load at 5.5Vdc/ 13.2Vdc	Maximum normal load at 5.5Vdc/ 13.2Vdc (Shift to Tma 60°C)	--	--
01.Ambient			24.1	60.0	--	--
For control board			--	--	--	--
02.PWB under U2			33.9	69.8	--	90
03.L1 coil			34.9	70.8	--	105
For converter board			--	--	--	--
04.PWB under U1			38.8	74.7	--	90
05.L1 coil			47.1	83.0	--	105
06.Panel body			30.6	66.5	--	95
07.Panel body (Rear)			35.6	71.5	--	--
Test duration:			1.9hrs	1.9hrs	--	--
For LCD Panel with DD Converter circuit Control board A			Maximum Normal Load at 3.6/13.2 Vdc	Maximum Normal Load at 3.6/13.2 Vdc, Shift to Tma 60	--	--
01.Ambient			23.5	60.0	--	--
02.L2 coil			29.5	66.0	--	105
03.PWB near U2			31.6	68.1	--	90
04.L4 coil			43.0	79.5	--	105
05.Panel body			30.3	66.8	--	95
06.Panel body rear			36.9	73.4	--	--
Test duration:			3.1hr	3.1hr	--	--
For LCD Panel with DD Converter circuit Control board B			Maximum Normal Load at 5.5/13.2 Vdc	Maximum Normal Load at 5.5/13.2 Vdc, Shift to Tma 60	--	--
01. Ambient			24.7	60.0	--	--
02. L2 coil			34.3	69.6	--	105
03. PWB near U5			34.5	69.8	--	90
04. L4 coil			41.5	76.8	--	105
05. PWB near U9			38.7	74.0	--	90
06. Panel body			32.4	67.7	--	95
07. Panel body (Rear)			36.8	72.1	--	--
Test duration :			1.4hrs	1.4hrs	--	--
For LCD Panel with DD Converter circuit Control board C			Maximum Normal Load at 3.6/13.2 Vdc	Maximum Normal Load at 3.6/13.2 Vdc, Shift to Tma 85	--	--
01. Ambient			23.3	85.0	--	--
02. L5 coil			45.9	107.6	--	125
03. PWB near U12			43.3	105	--	105
04. PWB near U5			40.3	102	--	105
05. L1 coil			34.1	95.8	--	105
06. PWB near U6			39.4	101.1	--	105

IEC 60950-1							
Clause	Requirement + Test			Result - Remark			Verdict
08. Mylar near Converter board	34.5	96.2	--	--	--	--	--
09. Panel body (Rear)	33.5	95.2	--	--	--	--	--
10. Panel body	32.8	94.5	--	--	--	--	95
Test duration:	2.2hrs	2.2hrs	--	--	--	--	--
For LCD Panel with DD Converter circuit Control board D	Maximum Normal Load at 3.6/13.2 Vdc	Maximum Normal Load at 3.6/13.2 Vdc, Shift to Tma 60	--	--	--	--	--
01. Ambient	22.8	60.0	--	--	--	--	--
02. PWB near U2	35.4	72.6	--	--	--	--	90
03. PWB near U7	36.3	73.5	--	--	--	--	90
04. LD01 Coil	36.8	74.0	--	--	--	--	105
05. LD02 Coil	36.1	73.3	--	--	--	--	105
06. LP1 Coil	52.7	89.9	--	--	--	--	105
07. PWB near UP1	45.6	82.8	--	--	--	--	90
08. Panel body (Rear)	26.3	63.5	--	--	--	--	--
09. Panel body	26.8	64.0	--	--	--	--	95
Test duration:	1.1hrs	1.1hrs	--	--	--	--	--
Supplementary information:							
Temperature T of winding:	t ₁ (°C)	R ₁ (Ω)	t ₂ (°C)	R ₂ (Ω)	T (°C)	Allowed T _{max} (°C)	Insulation class
--	--	--	--	--	--	--	--
Supplementary information:							
Comments: The temperatures were measured under worst case normal mode defined in 1.2.2.1 and as described in 1.6.1 at voltages as described in 1.6.5. With a specified ambient temperature of 60 degree C (excluding DD converter circuit control board C), 85 degree C (only for DD converter circuit control board C), the max. temperature is calculated as follows: Components with: - max. absolute temp. of 105 degree C (for other board) or 125 degree C (only for LCD Panel with DD Converter circuit Control board C) (Choke) - max. absolute temp. of 90 degree C (for other board) or 105 degree C (only for LCD Panel with DD Converter circuit Control board C) (PCB) User Accessible Area: - material is plastic 95 degree C							

4.5.5	TABLE: Ball pressure test of thermoplastic parts			N/A
	Allowed impression diameter (mm) :	≤ 2 mm		—
Part		Test temperature (°C)	Impression diameter (mm)	
--		--	--	
Supplementary information: --				

4.7	TABLE: Resistance to fire					N/A
Part		Manufacturer of material	Type of material	Thickness (mm)	Flammability class	Evidence
--		--	--	--	--	--

IEC 60950-1			
Clause	Requirement + Test	Result - Remark	Verdict

Supplementary information: To be evaluated in the end product.

5.1	TABLE: touch current measurement			N/A
Measured between:		Measured (mA)	Limit (mA)	Comments/conditions
--		--	--	--
--		--	--	--
Supplementary information:				
--				

5.2	TABLE: Electric strength tests, impulse tests and voltage surge tests			N/A
Test voltage applied between:		Voltage shape (AC, DC, impulse, surge)	Test voltage (V)	Breakdown Yes / No
Functional:				
--		--	--	--
Basic/supplementary:				
--		--	--	--
Reinforced:				
--		--	--	--
Supplementary information: --				

5.3	TABLE: Fault condition tests					N/A
	Ambient temperature (°C) :					--
	Power source for EUT: Manufacturer, model/type, output rating :					--
Component No.	Fault	Supply voltage (V)	Test time	Fuse #	Fuse current (A)	Observation
--	--	--	--	--	--	--
--	--	--	--	--	--	--
Supplementary information:						
Results Key:						
CT = Constant temperatures were obtained						
NB = No indication of dielectric breakdown						
NC = Cheesecloth remained intact						
NT = Tissue paper remained intact						
B = Circuit measures 0 volts.						

IEC 60950-1			
Clause	Requirement + Test	Result - Remark	Verdict

C.2	TABLE: transformers						N/A
Loc.	Tested insulation	Working voltage peak / V (2.10.2)	Working voltage rms / V (2.10.2)	Required electric strength (5.2)	Required clearance / mm (2.10.3)	Required creepage distance / mm (2.10.4)	Required distance thr. insul. (2.10.5)
--	--	--	--	--	--	--	--
Loc.	Tested insulation			Test voltage/ V	Measured clearance / mm	Measured creepage dist./ mm	Measured distance thr. insul. / mm; number of layers
--	--			--	--	--	--
supplementary information:							
--							

C.2	TABLE: transformers	N/A
Transformer --		